




Product Service

CERTIFICATE

No. Z2 120422 0008 Rev. 00

Holder of Certificate: **Qn-SOLAR PV LIMITED**
Unit 2 of LG 1, Mirror Tower, 61 Mody Road
999077 Tsim Sha Tsui, Kowloon
HONG KONG

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic (PV) Modules

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 882162325701

Valid until: 2028-08-13

Date, 2023-08-25


(Xinlian LUO)

CERTIFICATE

No. Z2 120422 0008 Rev. 00

Model(s):

With ½ cut of 210 mono c-Si cell (132pcs):
QNM210-HSxxx-66 (XXX=650-670, in step of 5)

With ½ cut of 210 mono c-Si cell (120pcs):
QNM210-HSxxx-60 (XXX=590-610, in step of 5)

With ½ cut of 210 mono c-Si cell (110pcs):
QNM210-HSxxx-55 (XXX=540-560, in step of 5)

With ⅓ cut of 210 mono c-Si cell (150pcs):
QNM210-HSxxx-50 (XXX=490-510, in step of 5)

With ½ cut of 182 mono c-Si cell (144pcs):
QNM182-HSxxx-72 (xxx=525-555, in step of 5)

With ½ cut of 182 mono c-Si cell (132pcs):
QNM182-HSxxx-66 (xxx=480-500, in step of 5)

With ½ cut of 182 mono c-Si cell (120pcs):
QNM182-HSxxx-60 (xxx=440-460, in step of 5)

With ½ cut of 182 mono c-Si cell (108pcs):
QNM182-HSxxx-54 (xxx=395-415, in step of 5)

With ½ cut of 210 mono c-Si cell (132pcs):
QNN210-HSxxx-66 (xxx=670-695, in step of 5)

With ½ cut of 210 mono c-Si cell (120pcs):
QNN210-HSxxx-60 (xxx=610-630, in step of 5)

With ½ cut of 210 mono c-Si cell (110pcs):
QNN210-HSxxx-55 (xxx=555-575, in step of 5)

With ½ cut of 182 mono c-Si cell (144pcs):
QNN182-HSxxx-72 (xxx=555-575, in step of 5)

With ½ cut of 182 mono c-Si cell (120pcs):
QNN182-HSxxx-60 (xxx=465-475, in step of 5)

With ½ cut of 182 mono c-Si cell (108pcs):

CERTIFICATE

No. Z2 120422 0008 Rev. 00

QNN182-HSxxx-54 (xxx=415-430, in step of 5)

xxx is standing for rated output power at STC

Parameters:

Safety Class: Class II

Max. System Voltage: 1500 V DC

Fire Safety Class: Class C according to UL790.

Severity mist test method 6

Construction: Framed, with Junction box, Cable and Connector.

Production Facilities:

1. Jiangsu Zhongqing Photovoltaic Technology Co., Ltd.

26, North Side of Taishan Road, Xiyi High-tech Zone, Xinyi City

Production Facility Number: 119915

2. ZhongQing Intelligence Industrial (HuBei) Co.,LTD.

Shuanglian Industrial Park, Dangyang Economic Development Zone, Hu-bei Province

Production Facility Number: 120038

Tested

according to:

IEC 61215-1:2016

IEC 61215-1-1:2016

IEC 61215-2:2016

IEC 61730-1:2016

IEC 61730-2:2016

IEC 61701:2020

IEC 62716:2013