



Certificate of Compliance

Certificate: 80045633

Master Contract: 274187

Project: 80111384

Date Issued: 2022-04-29

Issued To: Pylon Technologies Co., Ltd.
No. 73, Lane 887, Zu Chongzhi Road,
Zhangjiang Hi-Tech Park,
Pudong District, Shanghai, 201203
China

Attention: Lanqiang Li

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US

Issued by: Scola Chen
Scola Chen



PRODUCTS

CLASS - C370112 - BATTERY SYSTEM for use in Stationary Applications

CLASS - C370182 - BATTERY SYSTEM FOR USE IN STATIONARY APPLICATIONS Certified to US Standards

Rechargeable Lithium ion Battery Pack for use in stationary application, Model US3000C.

Electrical Ratings:

| Battery Pack Model | Battery Pack Ratings | | | | Battery Module |
|--------------------|----------------------|------------------------|-----------------------------|---------------------|----------------|
| | Normal Voltage, Vdc | Normal Capacity, Ah/Wh | Battery Pack Configuration* | Enclosure IP Rating | |
| US3000C | 48 | 74Ah/3552Wh | (2p5s) *3 | IP20 | XM1674 |

Note*: Battery Pack consists of 3 modules XM1674, which are in series connected. The Module XM1674 consists of 10pcs Cells, which are connected in 2 parallel-5 series configurations.



Certificate: 80045633
Project: 80111384

Master Contract: 274187
Date Issued: 2022-04-29

Manufacturer's Specified Charging Parameters for Battery Pack

| Battery Pack Model | Temperature Range, °C | Normal Charging Voltage, Vdc | Normal Charging Current, A | Maximum Charging Voltage, Vdc | Maximum Charging Current, A |
|--------------------|-----------------------|------------------------------|----------------------------|-------------------------------|---------------------------------------|
| US3000C | 0~50 | 53.5 | 37 | 54 | 74 (0~45 Deg. C) 37 (45~50 Deg. C) |

Manufacturer's Specified Discharging Parameters for Battery Pack:

| Battery Pack Model | Temperature Range, °C | Normal Discharging Current, A | End-of-discharge voltage, Vdc | Maximum Discharging Power, W | Maximum Discharging Current, A |
|--------------------|-----------------------|-------------------------------|-------------------------------|------------------------------|--------------------------------|
| US3000C | -10~50 | 37 | 40.5 | -- | 74 |

Conditions of Acceptability:

1. The battery pack including its battery management system has been tested according to the functional-safety requirements of ANSI/CAN/UL-1973:2018, Second Edition. Solid state circuits and software controls relied upon as the primary safety protection, have been evaluated to the Standard for Safety: Automatic Electrical Controls – Part 1, CSA/UL 60730-1. Any change to the software and electronic controls of the BMS may require additional testing.
2. The enclosure was evaluated only to establish an IP rating of IP20 with the Standard for Degrees of Protection Provided by Enclosure (IP Code) IEC 60529.
3. Product is evaluated for indoor use and shall avoid being used in moisture environment, and not being used near marine environments.
4. Further evaluation for Resistance of Moisture and/or Salt Fog shall be required for the battery pack intended to be used in the end product where moisture and/or salt fog condition were applied.
5. Manual disconnect device shall be required during the installation of the end products.
6. Corrosion due to electrochemical action is to be determined for conductive parts in contact with terminals when subjecting to the installation of the end products.
7. Equipment Application Location: Stationary
8. Access Location: Operator Accessible.
9. The installation was not evaluated. The battery system shall be installed in accordance with NFPA 70 or other applicable installation code.
10. Dielectric Voltage Withstand Test was performed with the test potential of 2000Vac/2828 Vdc, a higher test potential shall be considered in the end product if higher overvoltage category specified.
11. Overvoltage Category(OVC): 2
12. Pollution Degree(PD): 2
13. Altitude for Operation: Up to 2000 m.

APPLICABLE REQUIREMENTS



Certificate: 80045633

Master Contract: 274187

Project: 80111384

Date Issued: 2022-04-29

ANSI/CAN/UL-1973:2018, Second Edition - Batteries for Use in Stationary, Vehicle Auxiliary Power and Light Electric Rail (LER) Applications.

MARKINGS

See CSA report.

Notes:

Products certified under Class C370112, C370182 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 80045633

Master Contract: 274187

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

| Project | Date | Description |
|----------------|-------------|---|
| 80111384 | 2022-04-29 | Update report of 80045633. Added an alternate IC_CPU |
| 80045633 | 2020-10-30 | Original certification of Rechargeable Lithium ion Battery Pack for use in stationary application, Model US3000C. |